



No. 2014 - 0120

## Safety Certificate

- Manufacturer SEMI LIGHTING CO.,LTD..
- Address 328-32, Docheongwit-ro, Gwangju-Si, Gyeonggi-do, Korea

The following product fabricated by the above manufacturer has been certified for the use of the Safety Certification Mark as the product was assessed and tested in accordance with the article 34 of the Occupational Safety & Health Act and the article 58 (4) 4 of the Enforcement Rule thereof.

- Product LED Lighting Fixture(nR type)(HEAD ONLY)
- Type(Model) nR-L60-120-H-\*\*
- Rating AC 220V, 60Hz, Max 60W
- Type of Protection Ex nR II T5, IP66
- Certification No. 14-GA2BO-0120X
- Safety Certification Standards Notification of Protective device Mandatory Safety Certification (Notice of Ministry of Employment and of Labor No. 2013-54)
- Certification condition
  1. Tamb = - 20℃ ~ + 40℃
  2. Use Ex certified cable gland or sealing fitting more than IP66
  3. Each equipment shall be subjected to voltage test
- Date of issue March 20th, 2014

Approved for issue on behalf of the president : Ki-Youn Song  
position : General Manager

Signature



**Korea Gas Safety Corporation**